

STANDARD



ANSI/ASHRAE Standard 62.1-2022
(Supersedes ANSI/ASHRAE Standard 62.1-2019)
Includes ANSI/ASHRAE addenda listed in Appendix Q

Ventilation and Acceptable Indoor Air Quality

See Appendix Q for approval dates by ASHRAE and the American National Standards Institute.

This Standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the Standard. Instructions for how to submit a change can be found on the ASHRAE® website (www.ashrae.org/continuous-maintenance).

The latest edition of an ASHRAE Standard may be purchased from the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 180 Technology Parkway, Peachtree Corners, GA 30092. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2022 ASHRAE

ISSN 1041-2336



PDF includes hyperlinks for convenient navigation. Click on a reference to a section, table, figure, or equation to jump to its location. Return to the previous page via the bookmark menu.



Table 6-1 Minimum Ventilation Rates in Breathing Zone

Occupancy Category	People Outdoor Air Rate R_p		Area Outdoor Air Rate R_a		Default Values		
	cfm/ person	L/s· person	cfm/ft ²	L/s·m ²	Occupant Density		
					#/1000 ft ² or #/100 m ²	Air Class	OS (6.2.6.1.4)
Animal Facilities							
Animal exam room (veterinary office)	10	5	0.12	0.6	20	2	
Animal imaging (MRI/CT/PET)	10	5	0.18	0.9	20	3	
Animal operating rooms	10	5	0.18	0.9	20	3	
Animal postoperative recovery room	10	5	0.18	0.9	20	3	
Animal preparation rooms	10	5	0.18	0.9	20	3	
Animal procedure room	10	5	0.18	0.9	20	3	
Animal surgery scrub	10	5	0.18	0.9	20	3	
Large-animal holding room	10	5	0.18	0.9	20	3	
Necropsy	10	5	0.18	0.9	20	3	
Small-animal-cage room (static cages)	10	5	0.18	0.9	20	3	
Small-animal-cage room (ventilated cages)	10	5	0.18	0.9	20	3	
Correctional Facilities							
Booking/waiting	7.5	3.8	0.06	0.3	50	2	
Cell	5	2.5	0.12	0.6	25	2	
Dayroom	5	2.5	0.06	0.3	30	1	
Guard stations	5	2.5	0.06	0.3	15	1	
Educational Facilities							
Art classroom	10	5	0.18	0.9	20	2	
Classrooms (ages 5 to 8)	10	5	0.12	0.6	25	1	
Classrooms (age 9 plus)	10	5	0.12	0.6	35	1	
Computer lab	10	5	0.12	0.6	25	1	
Daycare sickroom	10	5	0.18	0.9	25	3	
Daycare (through age 4)	10	5	0.18	0.9	25	2	
Lecture classroom	7.5	3.8	0.06	0.3	65	1	✓
Lecture hall (fixed seats)	7.5	3.8	0.06	0.3	150	1	✓
Libraries	5	2.5	0.12	0.6	10		
Media center	10	5	0.12	0.6	25	1	
Multiuse assembly	7.5	3.8	0.06	0.3	100	1	✓
Music/theater/dance	10	5	0.06	0.3	35	1	✓
Science laboratories	10	5	0.18	0.9	25	2	
University/college laboratories	10	5	0.18	0.9	25	2	
Wood/metal shop	10	5	0.18	0.9	20	2	
Food and Beverage Service							
Bars, cocktail lounges	7.5	3.8	0.18	0.9	100	2	

Table 6-1 Minimum Ventilation Rates in Breathing Zone (Continued)

Occupancy Category	People Outdoor Air Rate R_p		Area Outdoor Air Rate R_a		Default Values		
	cfm/ person	L/s· person	cfm/ft ²	L/s·m ²	Occupant Density		
					#/1000 ft ² or #/100 m ²	Air Class	OS (6.2.6.1.4)
Cafeteria/fast-food dining	7.5	3.8	0.18	0.9	100	2	
Kitchen (cooking)	7.5	3.8	0.12	0.6	20	2	
Restaurant dining rooms	7.5	3.8	0.18	0.9	70	2	
General							
Break rooms	5	2.5	0.06	0.3	25	1	✓
Coffee stations	5	2.5	0.06	0.3	20	1	✓
Conference/meeting	5	2.5	0.06	0.3	50	1	✓
Corridors	—	—	0.06	0.3	—	1	✓
Occupiable storage rooms for liquids or gels	5	2.5	0.12	0.6	2	2	
Hotels, Motels, Resorts, Dormitories							
Barracks sleeping areas	5	2.5	0.06	0.3	20	1	✓
Bedroom/living room	5	2.5	0.06	0.3	10	1	✓
Laundry rooms, central	5	2.5	0.12	0.6	10	2	
Laundry rooms within dwelling units	5	2.5	0.12	0.6	10	1	
Lobbies/prefunction	7.5	3.8	0.06	0.3	30	1	✓
Multipurpose assembly	5	2.5	0.06	0.3	120	1	✓
Miscellaneous Spaces							
Banks or bank lobbies	7.5	3.8	0.06	0.3	15	1	✓
Bank vaults/safe deposit	5	2.5	0.06	0.3	5	2	✓
Computer (not printing)	5	2.5	0.06	0.3	4	1	✓
Freezer and refrigerated spaces (<50°F [10°C])	10	5	0	0	0	2	
Manufacturing where hazardous materials are not used	10	5.0	0.18	0.9	7	2	
Manufacturing where hazardous materials are used (excludes heavy industrial and chemical processes)	10	5.0	0.18	0.9	7	3	
Pharmacy (prep. area)	5	2.5	0.18	0.9	10	2	
Photo studios	5	2.5	0.12	0.6	10	1	
Shipping/receiving	10	5	0.12	0.6	2	2	
Sorting, packing, light assembly	7.5	3.8	0.12	0.6	7	2	
Telephone closets	—	—	0.00	0.0	—	1	
Transportation waiting	7.5	3.8	0.06	0.3	100	1	✓
Warehouses	10	5	0.06	0.3	—	2	
Office Buildings							
Breakrooms	5	2.5	0.12	0.6	50	1	
Main entry lobbies	5	2.5	0.06	0.3	10	1	✓

Table 6-1 Minimum Ventilation Rates in Breathing Zone (Continued)

Occupancy Category	People Outdoor Air Rate R_p		Area Outdoor Air Rate R_a		Default Values		
	cfm/ person	L/s· person	cfm/ft ²	L/s·m ²	Occupant Density		
					#/1000 ft ² or #/100 m ²	Air Class	OS (6.2.6.1.4)
Occupiable storage rooms for dry materials	5	2.5	0.06	0.3	2	1	
Office space	5	2.5	0.06	0.3	5	1	✓
Reception areas	5	2.5	0.06	0.3	30	1	✓
Telephone/data entry	5	2.5	0.06	0.3	60	1	✓
Public Assembly Spaces							
Auditorium seating area	5	2.5	0.06	0.3	150	1	✓
Courtrooms	5	2.5	0.06	0.3	70	1	✓
Legislative chambers	5	2.5	0.06	0.3	50	1	✓
Libraries	5	2.5	0.12	0.6	10	1	
Lobbies	5	2.5	0.06	0.3	150	1	✓
Museums (children's)	7.5	3.8	0.12	0.6	40	1	
Museums/galleries	7.5	3.8	0.06	0.3	40	1	✓
Places of religious worship	5	2.5	0.06	0.3	120	1	✓
Residential							
Common corridors	—	—	0.06	0.3		1	✓
Retail							
Sales (except as below)	7.5	3.8	0.12	0.6	15	2	
Barbershop	7.5	3.8	0.06	0.3	25	2	✓
Beauty and nail salons	20	10	0.12	0.6	25	2	
Coin-operated laundries	7.5	3.8	0.12	0.6	20	2	
Mall common areas	7.5	3.8	0.06	0.3	40	1	✓
Pet shops (animal areas)	7.5	3.8	0.18	0.9	10	2	
Supermarket	7.5	3.8	0.06	0.3	8	1	✓
Sports and Entertainment							
Bowling alley (seating)	10	5	0.12	0.6	40	1	
Disco/dance floors	20	10	0.06	0.3	100	2	✓
Gambling casinos	7.5	3.8	0.18	0.9	120	1	
Game arcades	7.5	3.8	0.18	0.9	20	1	
Gym, sports arena (play area)	20	10	0.18	0.9	7	2	
Health club/aerobics room	20	10	0.06	0.3	40	2	
Health club/weight rooms	20	10	0.06	0.3	10	2	
Spectator areas	7.5	3.8	0.06	0.3	150	1	✓
Stages, studios	10	5	0.06	0.3	70	1	✓
Swimming (pool and deck)	—	—	0.48	2.4	—	2	

Table 6-2 Minimum Exhaust Rates

Occupancy Category	Exhaust Rate, cfm/unit	Exhaust Rate, cfm/ft ²	Notes	Exhaust Rate, L/s·unit	Exhaust Rate, L/s·m ²	Air Class
Animal Facilities						
Animal imaging (MRI/CT/PET)	—	0.90		—	4.5	3
Animal operating rooms	—	3.00		—	15	3
Animal postoperative recovery room	—	1.50		—	7.5	3
Animal preparation rooms	—	1.50		—	7.5	3
Animal procedure room	—	2.25		—	11.3	3
Animal surgery scrub	—	1.50		—	7.5	3
Large-animal holding room	—	2.25		—	11.3	3
Necropsy	—	2.25		—	11.3	3
Small-animal-cage room (static cages)	—	2.25		—	11.3	3
Small-animal-cage room (ventilated cages)	—	1.50		—	7.5	3
Arenas	—	0.50	B	—	—	1
Art classrooms	—	0.70		—	3.5	2
Auto repair rooms	—	1.50	A	—	7.5	2
Barber shops	—	0.50		—	2.5	2
Beauty and nail salons	—	0.60		—	3.0	2
Cells with toilet	—	1.00		—	5.0	2
Copy, printing rooms	—	0.50		—	2.5	2
Darkrooms	—	1.00		—	5.0	2
Educational science laboratories	—	1.00		—	5.0	2
Janitor closets, trash rooms, recycling	—	1.00		—	5.0	3
Kitchenettes	—	0.30		—	1.5	2
Kitchens—commercial	—	0.70		—	3.5	2
Locker rooms for athletic, industrial, and health care facilities	—	0.50		—	2.5	2
All other locker rooms	—	0.25	—	—	1.25	2
Shower rooms	20/50	—	G,I	10/25	—	2
Paint spray booths	—	—	F	—	—	4
Parking garages	—	0.75	C	—	3.7	2
Pet shops (animal areas)	—	0.90	—	—	4.5	2
Refrigerating machinery rooms	—	—	F	—	—	3
Residential kitchens	50/100	—	G	25/50	—	2
Soiled laundry storage rooms	—	1.00	F	—	5.0	3
Storage rooms, chemical	—	1.50	F	—	7.5	4
Toilets—private	25/50	—	E, H	12.5/25	—	2
Toilets—public	50/70	—	D, H	25/35	—	2
Woodwork shop/classrooms	—	0.50	—	—	2.5	2

NOTES:

- A Stands where engines are run shall have exhaust systems that directly connect to the engine exhaust and prevent escape of fumes.
- B Where combustion equipment is intended to be used on the playing surface, additional dilution ventilation, source control, or both shall be provided.
- C Exhaust shall not be required where two or more sides compose walls that are at least 50% open to the outside.
- D Rate is per water closet, urinal, or both. Provide the higher rate where periods of heavy use are expected to occur. The lower rate shall be permitted to be used otherwise.
- E Rate is for a toilet room intended to be occupied by one person at a time. For continuous system operation during hours of use, the lower rate shall be permitted to be used. Otherwise the higher rate shall be used.
- F See other applicable standards for exhaust rate.
- G For continuous system operation, the lower rate shall be permitted to be used. Otherwise the higher rate shall be used.
- H Exhaust air that has been cleaned to meet Class 1 criteria from Section 5.13.1 shall be permitted to be recirculated.
- I Rate is per showerhead.